



icmr
INDIAN COUNCIL OF
MEDICAL RESEARCH
Serving the nation since 1911

NIV
NATIONAL INSTITUTE
OF VIROLOGY

आई सी एम आर - राष्ट्रीय विषाणु विज्ञान संस्थान

स्वास्थ्य अनुसंधान विभाग
स्वास्थ्य एवं परिवार कल्याण मंत्रालय, भारत सरकार

ICMR - NATIONAL INSTITUTE OF VIROLOGY

Department of Health Research
Ministry of Health & Family Welfare, Govt. of India

PP no. 1709/NIV-Purchase/2023-24

Dt. 8th Aug, 2023

QUOTATION ENQUIRY


Sealed quotations are invited on behalf of the Director, ICMR-National Institute of Virology, Pune for "Split A.C". Interested vendors should submit their quotation along with their company/personal profile and details given below:

Sl. No	Equipment	Qty. Required	Remarks
1	Split A.C (2 Ton Non inverter, Min. 3 Star Supply, Installation & Commissioning - Installation as per our requirement).	1	Specifications copy attached (Quotation to be submitted after inspection of site - ICMR NIV, MCC 130/1, Sus Road, Pashan, Pune -411021). Room no. 215, J.E Dept.

The quotation super scribed as "Quotation for PP no. 1709 Split A.C" addressed to the Director, ICMR-National Institute of Virology, 20-A, Dr. Ambedkar Road, P.B. No.11, PUNE -411 001. (Attention: Administrative officer - Stores), should be either dropped at the Stores Department at NIV Pune or sent through Speed Post/Courier latest by 29th Aug, 2023 till 5.00 p.m.

OTHER TERMS & CONDITIONS

1. This is an enquiry and must not be treated as an order.
2. The NIV, Pune office reserves the right to accept or reject any or all applicants without assigning any reasons.
3. Any decision taken by the Director, NIV Pune at any point of time in connection with this process shall be final and conclusive and no claim or dispute from any quarter in that regard shall be entertained.
4. No advance payment will be made. The payment will be made on receipt of services availed and satisfactory report of the end users.
5. NIV, Pune will not be responsible for any delay for receipt of quotations.
6. Requirement of Split A.C will either increase or decrease final requirement will be mentioned in the P.O order issued to the firm.


Administrative Officer

Specification of Non inverter Split AC

Supply Installation & Testing of Split AC

Capacity: 2 Ton Non inverter,

Rating: Min 3 star

Power: Single phase, 230 V,

Location of indoor unit: - Room No. - 215 Bucer

Location of outdoor: External side of building on the wall at ground floor

All materials are copper (Indoor, Outdoor unit and necessary piping)

Indoor to outdoor copper piping with insulation: Approx. 25 feet

Three core copper cable. Approx. 20 feet

Provision of hard drain piping for indoor to outside chamber area: Approx. 25 feet

Provision of outer door stand

Necessary core cutting & civil work required for closing of openings Bucer

Note: Quotation may please be submitted after inspection of site

Rayan
25/07/2023

Bucer